



Concept Design
QIC Building

ARCH-BIO
Architecture with a Bioclimatic Approach

PROJECT TEAM

NAME OF STAFF	POSITION	TASK
Marco Santiago Morales Flores	Project Manager	Entire team and project process manager including architectural and engineering plans.
Mauro Rodolfo Cepeda Ortiz	Lead architect	Principal architect and architectural design team leader.
Jose Luis Yela Guevara	Architectural coordinator	Architectural design, rendering and blueprints coordinator.
Diego Augusto Lara Sosa	Structural Designer	Structural designer and team leader.
Fabricio Lenin Vasco Vera	Electrical engineer	Electrical designer and team leader.
Francisco Javier Vallejo Jaramillo	Mechanical engineer / plumbing engineer	Mechanical and plumbing designer, team leader.
Carolina Delgado del Hierro	Landscape designer	Main landscape designer.

CLIMATE SITE ANALYSIS

ARCH


Architecture with a Bioclimatic Approach

BIO

AVERAGE MONTHLY TEMPERATURE



- ① MONTHS WITH MAXIMUM HEAT DISCOMFORT
- ② MONTHS WITH MAXIMUM COLD DISCOMFORT
- ③ MAXIMUM AVERAGE TEMPERATURE
- ④ MINIMUM AVERAGE TEMPERATURE
- ⑤ WIDE THERMAL GRADIENT




26°C
MAXIMUM
TEMPERATURE


4°C
MINIMUM
TEMPERATURE

18°C- 24°C
THERMAL COMFORT RANGE

MONTHLY TEMPERATURE PER HOUR AND RELATIONSHIP WITH RADIATION



- ① MONTHS WITH MAXIMUM HEAT DISCOMFORT
- ② MONTHS WITH MAXIMUM COLD DISCOMFORT
- ③ MAXIMUM AVERAGE TEMPERATURE
- ④ MINIMUM AVERAGE TEMPERATURE
- ⑤ WIDE THERMAL GRADIENT
- ⑥ AVERAGE TEMPERATURE LINE - DRY BULB
- ⑦ AVERAGE TEMPERATURE LINE - WET BULB
- ⑧ COMFORT RANGE




ARCH


Architecture with a Bioclimatic Approach

BIO


9:00 A.M. SEPTEMBER 21 - EQUINOX




12:00 P.M. SEPTEMBER 21 - EQUINOX




3:00 P.M. SEPTEMBER 21 - EQUINOX





9:00 A.M. JUNE 21 - SOLSTICE




12:00 P.M. JUNE 21 - SOLSTICE




3:00 P.M. JUNE 21 - SOLSTICE




The "Revit Daylight Analysis" determined the daily intake of light with the current façade. The result showed that most of the spaces do not receive enough natural light, so artificial light is needed during major part of the day.




SPEED A T 10M MINIMUN (1.92 M/S)




SPEED A T 10M RANGE (4,56 M/S)




DIRECTION'S WINDROSE



SPEED A T 10M MAXIMUM (11.83 M/S)



SPEED A T 10M RANGE (4,56 M/S)



BEAUFORT WIND SCALE

EFFECT	WIND SPEED MTRS/SEC	DESCRIPTION	EFFECT	WIND SPEED MTRS/SEC	DESCRIPTION
	0.5-1.5	Calm, smoke rises vertically		10.5-13.5	High wind, moderate gale, trees gale, whole trees in motion
	1.6-3.3	Light air, direction shown by smoke drift		13.6-17.1	Gale, fresh gale, large break off trees
	3.4-6.2	Light breeze, wind felt on face		17.2-20.7	Strong breeze, slight structural damage
	6.3-10.4	Good breeze, leaves and small flags in constant motion		20.8-24.4	Storm, whole gale, trees sprouted, considerable structural damage
	10.5-13.5	Moderate breeze, raises dust and loose paper		24.5-28.1	Violent storm, widespread damage
	13.6-17.1	Strong breeze, small trees and flags begin to sway		28.2-31.8	Hurricane force, destruction

The largest wind flow comes from the North at an average speed of 4.56 m/s. This speed, according to the Beaufort scale, is in the "comfortable wind" range, but is on the limit of becoming "too strong". Therefore, the North façade would be a good angle for the entry of wind.

It is important to consider that another building (not part of the intervention) blocks the North façade, consequently, the direction of the wind within the project causes very low air exchange, so air movement must be created mechanically to obtain a suitable work environment for the staff.

BIOCLIMATIC PROJECT REQUIREMENTS

ARCH

Architecture with a Bioclimatic Approach

BIO

ZONE	ROOM	NOTES	NET AREA	TEMPERATURE	ILUMINATION						VENTILATION								ACUSTIC COMFORT
					ILUMINATION LEVEL (LUX)			RECOMMENDED TONES OF LIGHT			NATURAL			MECHANICAL			PREVENTIVE		
					MIN	GOOD	VERY GOOD	DAY LIGHT	WHITE	WARM WHITE	LATERAL VENTILATION	CROOSSED VENTILATION	INTERCONNECTION WITH ZONE VENTILATED	INDOOR AIR EXTRACTION	AIR CONDITIONING	AIR PURIFIER INTERIORS	PRE - VENTILATION	CHANGE OF SPEED OF AIR RENEWAL CONDITIONED	
Business incubation & acceleration	Tenant Office (S)	Office for 2-3 people	210 (30*7EA)	18 °C	300	500	1000		X	X	X	X	X	X	X		X	X	45
	Tenant Office (M)	Office for 3-5 people	250 (50*7EA)	18 °C	300	500	1000		X	X	X	X	X	X	X		X	X	45
	Tenant Office (L)	Office for 5-7 people	210 (70*7EA)	18 °C	300	500	1000		X	X	X	X	X	X	X		X	X	45
	Co - working	For 10-15 people	110	18 °C	500	700	1200	X	X		X	X	X	X		X	X	X	50
SME development	Tenant Office (XL)		400 (200*2EA)	18 °C	300	500	1000		X	X	X	X	X	X	X		X	X	50
Research	ICT Lab	For basic prototyping, IoT technologies and A.I.	200	18 °C	250	400	600	X	X		X	X		X	X		X	X	40
	Research Lab	Adaptive & flexible. Can be divided in to 2 rooms	120	18 °C	300	500	1000	X	X		X	X		X	X		X	X	40
Administration	Director's		30	18 °C	300	500	1000		X	X	X	X	X	X	X		X	X	40
	Office	Open plan office	70	18 °C	300	500	1000		X	X	X	X	X	X	X		X	X	45
Public	Meeting room (S)	4-5 People	40 (20*EA)	18 °C	200	500	1000		X	X	X	X	X	X			X		45
	Meeting room (M)	5-8 People	30	18 °C	200	500	1000		X	X	X	X	X	X			X		45
	Meeting room (L)	10-12 People	50	18 °C	500	700	1000		X	X	X	X	X	X			X		45
	Seminar room	Lecture & training	130	18 °C	200	500	100		X	X				X	X	X	X	X	35
	Café	Including kitchen	160	18 °C	200	400	700		X	X				X	X	X	X	X	35
	Show room/Exhibit		150	18 °C	1000	2000	3000	X	X	X				X	X		X	X	50
	Mechanical & electrical	Generator, transformer	60	15 °C	100	200	400		X	X	X	X	X	X	X	X	X	X	15
Utilities	Server		30	15 °C	100	200	400		X	X	X	X	X	X	X	X	X	X	15
	Loading & waste		70	15 °C	200	300	500	X	X		X	X	X	X	X	X	X	X	15
	Storage		100	18 °C	200	300	500	X	X		X	X	X	X	X	X	X	X	15
NET AREA TOTAL					2420						2420								
Common	Lobby, vertical transportation, restroom, janitor's		680	18 °C	300	500	700		X	X	X	X		X		X			15
GROSS FLOOR AREA					3100						3100								

Recommended bioclimatic parameters to be applied in the design

Inner Comfort : 18°C – 24 °C

Natural Ventilation: 1,8 m/s – 4 m/s (Beaufort Scale)

Natural Illumination: 230 lux – 400 lux

Acoustic Parameters: 30 - 40 dB

ARCH

Architecture with a Bioclimatic Approach

BIO

CURRENT BUILDING




BIOCLIMATIC AND PERFORMANCE ANALYSIS

ARCH

Architecture with a Bioclimatic Approach

BIO

RADIATION




ARCH


Architecture with a Bioclimatic Approach

BIO


DAYLIGHTING ANALYSIS




9:00 A.M.



3:00 P.M.



BOTH



RESULTS SUMMARY FOR ALL ROOMS INCLUDED IN DAYLIGHTING EQUINOX

9:00 a.m. – 75% Passing

September 21
GHI:637, DNI:833, DHI:66
25% below threshold
0% above threshold w/o shades

Total Both – 3% Passing

97% either time below threshold
0% either time above threshold

3:00 p.m. – 3% Passing

September 21
GHI:172, DNI:212, DHI:17
97% below threshold
0% above threshold w/o shades

RESULTS SUMMARY FOR ALL ROOMS INCLUDED IN DAYLIGHTING EQUINOX

9:00 a.m. – 75% Passing

June 21
GHI:522, DNI:761, DHI:64
25% below threshold
0% above threshold w/o shades

Total Both – 3% Passing




97% either time below threshold
0% either time above threshold

3:00 p.m. – 3% Passing


June 21
GHI:156, DNI:202, DHI:16
97% below threshold
0% above threshold w/o shades

CLIMATE GENERAL DIAGNOSIS

SUNLIGHT INCOME



7:00 A.M.



11:00 A.M.

ARCH

Architecture with a Bioclimatic Approach

BIO

OPTION 1

(Glass Facade)


INTERIOR DAYLIGHT



LOW RADIATION RANGE



INTERIOR AIR EXCHANGE



OPTION 2

(Lattice Facade)


INTERIOR DAYLIGHT



LOW RADIATION RANGE



INTERIOR AIR EXCHANGE



OPTION 3

(Lattice and Glass Facade)


INTERIOR DAYLIGHT



LOW RADIATION RANGE



INTERIOR AIR EXCHANGE



OPTION 4

(Extruding elements)


INTERIOR DAYLIGHT



LOW RADIATION RANGE



INTERIOR AIR EXCHANGE



BEST ARCHITECTURAL OPTION CONFIGURATION



BIOCLIMATIC AND PERFORMANCE OPTION 4

ARCH




Architecture with a Bioclimatic Approach

Bio

RADIATION



MADE IN: AUTODESK REVIT, AUTODESK FORMIT




ARCH


Architecture with a Bioclimatic Approach

BIO


DAYLIGHTING ANALYSIS




9:00 A.M.



3:00 P.M.



BOTH



RESULTS SUMMARY FOR ALL ROOMS INCLUDED IN DAYLIGHTING EQUINOX

9:00 a.m. – 81% Passing

September 21
GHI:637, DNI:833, DHI:66
25% below threshold
0% above threshold w/o shades

Total Both – 14% Passing

97% either time below threshold
0% either time above threshold

3:00 p.m. – 14% Passing

September 21
GHI:172, DNI:212, DHI:17
97% below threshold
0% above threshold w/o shades

RESULTS SUMMARY FOR ALL ROOMS INCLUDED IN DAYLIGHTING EQUINOX

9:00 a.m. – 81% Passing

June 21
GHI:522, DNI:761, DHI:64
25% below threshold
0% above threshold w/o shades

Total Both – 12% Passing

97% either time below threshold
0% either time above threshold

3:00 p.m. – 12% Passing

June 21
GHI:156, DNI:202, DHI:16
97% below threshold
0% above threshold w/o shades

ARCH

Architecture with a Bioclimatic Approach


BIO

BIOCLIMATIC APPLIED STRATEGIES


1 GREEN INPUT




2 SKIN/RADIATION ORIEN




3 DIFFUSE SIDE LIGHTING




4 SOLAR TUBES




5 FACADE OPENINGS





6 SUN COMFORT




7 RAIN WATER COLLECTION



8 AIR EXCHANGE



SUSTAINABLE APPLIED STRATEGIES



219.20
KWH / YEAR

REGULAR ENERGY
CONSUMPTION

149.40
KWH / YEAR

OPTIMUM ENERGY
CONSUMPTION



20.56
M3 X DAY

REGULAR WATER
CONSUMPTION

10.28
M3 X DAY

OPTIMUM WATER
CONSUMPTION

TEMPERED GLASS

VRF SYSTEM
AIR-CONDITIONING

LATTICE FACADE

BIOPHILIA

SOLAR TUBES



20%



ARCH

Architecture with a Bioclimatic Approach

BIO


ARCHITECTURAL PROPOSAL

ARCH

Architecture with a Bioclimatic Approach

BIO

SITE UTILITY PLAN



SME DEVELOPMENT

- TENANT OFFICE XL (1)
- TENANT OFFICE XL (2)

BUSINESS INCUBATION & ACCELERATION

- TENANT OFFICE S
- TENANT OFFICE M
- TENANT OFFICE L
- COWORKING

PUBLIC

- MEETING ROOM (S)
- mEETING ROOM (M)
- MEETING ROOM (L)
- SEMINAR ROOM
- CAFE
- EXHIBITION


PUBLIC

- LOBBY
- VERTICAL TRANSPORTATION
- RESTROOMS
- JANITOR

UTILITIES

- MECHANICAL & ELECTRICAL
- SERVER
- LOADING & WASTE
- STORAGE

SITE UTILITY PLAN



ADMINISTRATION

- OPEN PLAN OFFICE
- DIRECTOR

RESEARCH

- RESEARCH LAB
- ITC LAB

FLOOR PLAN – GROUND FLOOR



ZONE	ROOM	NOTES	NET AREA
Business incubation & acceleration	Tenant Office (S)	Office for 2-3 people	279,83
	Tenant Office (M)	Office for 3-5 people	248,16
	Tenant Office (L)	Office for 5-7 people	220,31
	Co - working	For 10-15 people	106,65
SME development	Tenant Office (XL)		361,78
Research	ICT Lab	For basic prototyping, IoT technologies and A.I.	183,7
	Research Lab	Adaptive & flexible. Can be divided in to 2 rooms	119,06
Administration	Director's		29,68
	Office	Open plan office	106,5
Public	Meeting room (S)	4-5 People	38,56
	Meeting room (M)	5-8 People	40
	Meeting room (L)	10-12 People	53,68
	Seminar room	Lecture & training	134,11
	Café	Including kitchen	163,25
	Show room/Exhibit		199,1
Utilities	Mechanical & electrical	Generator, transformer	79,93
	Server		29,92
	Loading & waste		81,74
	Storage		103,68
NET AREA TOTAL			2579,64
Common	Lobby, vertical transportation, restroom, janitor's		620,36
GROSS FLOOR AREA			3200


GROUND FLOOR: 2.641,06 m2

ARCH

Architecture with a Bioclimatic Approach

BIO

FLOOR PLAN – GROUND FLOOR



ZONE	ROOM	NOTES	NET AREA
Business incubation & acceleration	Tenant Office (S)	Office for 2-3 people	279,83
	Tenant Office (M)	Office for 3-5 people	248,16
	Tenant Office (L)	Office for 5-7 people	220,31
	Co - working	For 10-15 people	106,65
SME development	Tenant Office (XL)		361,78
Research	ICT Lab	For basic prototyping, IoT technologies and A.I.	183,7
	Research Lab	Adaptive & flexible. Can be divided in to 2 rooms	119,06
Administration	Director's	Open plan office	29,68
	Office		106,5
Public	Meeting room (S)	4-5 People	38,36
	Meeting room (M)	5-8 People	40
	Meeting room (L)	10-12 People	53,68
	Seminar room	Lecture & training	134,11
	Café	Including kitchen	163,25
	Show room/Exhibit		199,1
Utilities	Mechanical & electrical	Generator, transformer	79,93
	Server		29,92
	Loading & waste		81,74
	Storage		103,68
NET AREA TOTAL			2579,64
Common	Lobby, vertical transportation, restroom, janitor's		620,36
GROSS FLOOR AREA			3200

MEZZANINE : 558,94 m2




FLOOR PLAN MEZZ


ARCH

Architecture with a Bioclimatic Approach

BIO

ELEVATIONS







ARCH-BIO[®]
Architecture with a Bioclimatic Approach







PROPOSAL VIDEO



ARCH

Architecture with a Bioclimatic Approach

BIO

Thanks for your attention !!



ARCH-BIO[®]
Architecture with a Bioclimatic Approach

@ArchBIOec
www.arch-bioec.com

